



# North Liberty Fire Department

25 W. Cherry St., North Liberty, IA

Phone: (319) 626-5717 Fax: (319) 626-3238

## Fire Alarm & Fire Protection Equipment Room Signage Requirements

The exterior of the entry door to the room where the Fire Alarm Panel is located shall have following signage requirements.

### Fire Alarm Panel Room:

- The exterior of the Entry Door to the Fire Alarm Panel Room shall be labeled "Fire Alarm Panel". Sign shall be placed on the outside of the entry door.
- White Sign with Red Letters and Red Solid Border. Minimum of 5" x 7"

