



North Liberty Fire Department

25 W. Cherry St., North Liberty, IA

Phone: (319) 626-5717 Fax: (319) 626-3238

Roof Access Signage Requirements

The exterior of the entry door to the room where the Roof Access is located shall have following signage requirements.

The exterior of the Entry Door to the Roof Access shall be labeled "Roof Access"

White Sign with Red Letters and Red Solid Border. Minimum of 6" x 12"

