



North Liberty Fire Department

25 W. Cherry St., North Liberty, IA

Phone: (319) 626-5717 Fax: (319) 626-3238

The Sprinkler Room & Fire Alarm Room shall comply with the following signage requirements.

Sprinkler System:

- Entry Door to the Sprinkler Room shall be labeled "Fire Sprinkler Shut-Off Valve", sign shall be placed on the outside of the entry door.
- White Sign with Red Letter. Minimum of 5" x 7".

