



Requirement:

Commercial cooking automatic fire extinguishing systems installed in buildings that do not have a fire alarm system, shall be connected to an approved audible and visible emergency notification device to warn of system discharge.

**HOOD SUPPRESSION
SYSTEM ACTIVATION
-WHEN SOUNDING-
CALL 911**

Sign requirements:

- Red sign with White Letters
- Plastic or Metal
- Minimum size: 10"x7"
- Mount on wall in close proximity of Kitchen Hood Suppression system audible/visual warning device

Horn/Strobe requirements:

- Horn/strobe shall be installed in the kitchen at a location approved by the fire code official.
- Horn/strobe shall be mounted in a location that will not be obstructed from view.
- Single horn/strobe shall activate upon kitchen hood suppression system activation.
- Shall turn off/reset when the kitchen hood suppression system is reset.
- Horn/strobe can be ceiling or wall mounted.
- Wall mounted horn/strobes devices shall be mounted so the entire strobe lens is between 80" – 96" from finished floor.

