



North Liberty Fire Department Signage Requirement

Fire Command Center Room Signage



Minimum Size: 5" x 7"

Lettering: Red lettering on white background with solid red border

Installation: Post on the exterior of the door to the room where each Fire Command Center is located