



# North Liberty Fire Department Signage Requirement

## Fire Sprinkler Riser Equipment Room Signage



**Minimum Size:** 5" x 7"

**Lettering:** Red lettering on white background with solid red border

**Installation:** Post on the exterior of the door to the room where each Sprinkler Riser is located