



North Liberty Fire Department Signage Requirement

Motor Fueling-Dispensing Facilities Dispenser Warning Sign

Warning Signs shall include the following language (or similar):

1. No smoking
2. Shut off motor
3. Discharge your static electricity before fueling by touching a metal surface away from the nozzle
4. To prevent static charge, do not reenter your vehicle while gasoline is pumping
5. If a fire starts, do not remove nozzle—back away immediately
6. It is unlawful and dangerous to dispense gasoline into unapproved containers
7. No filling of portable containers in or on a motor vehicle. Place container on ground before filling.

Example:

WARNING

SELF SERVE

- NO SMOKING.
- STOP ENGINE.
- PERSONS USING DISPENSERS WITH HOLD-OPEN LATCHES MUST REMAIN AT THE REFUELING POINT (OUTSIDE VEHICLE) DURING REFUELING.

STATIC ELECTRICITY/ SPARK EXPLOSION HAZARD

- DISCHARGE STATIC ELECTRICITY BEFORE REFUELING BY TOUCHING A METAL SURFACE AWAY FROM NOZZLE.
- DO NOT GET BACK IN YOUR VEHICLE WHILE REFUELING, RE-ENTRY COULD CAUSE A STATIC BUILD UP.
- IF FIRE STARTS, DO NOT REMOVE NOZZLE-BACK AWAY IMMEDIATELY.

GASOLINE HEALTH & SAFETY

- EXTREMELY FLAMMABLE, VAPORS MAY EXPLODE.
- HARMFUL OR FATAL IF SWALLOWED.
- LONG-TERM EXPOSURE TO VAPORS HAS CAUSED CANCER IN LABORATORY ANIMALS.
- KEEP FACE AWAY FROM NOZZLE WHILE FILLING.
- KEEP NOZZLE AWAY FROM EYES AND SKIN.
- NEVER SYPHON BY MOUTH.
- DON'T OVERFILL TANK.
- DON'T ALLOW INDIVIDUALS UNDER LICENSE AGE TO USE PUMP.

FOR USE AS A MOTOR FUEL ONLY

PORTABLE CONTAINER

- IT IS UNLAWFUL AND DANGEROUS TO DISPENSE MOTOR FUELS INTO UNAPPROVED CONTAINERS.
- NO FILLING OF PORTABLE CONTAINERS IN OR ON A MOTOR VEHICLE. PLACE CONTAINER ON GROUND BEFORE FILLING.
- KEEP NOZZLE IN CONTACT WITH CONTAINER.

Minimum Size: No specific requirement

Lettering: No specific requirement

Installation: Warning signs shall be conspicuously posted within sight of each dispenser in the fuel-dispensing area and shall state the following: