



North Liberty Fire Department Signage Requirement

Natural Gas Fire Pit Emergency Shutoff Signage



Minimum Size: 4" x 6"

Lettering: Red lettering on white background with solid red border -or- White lettering on red background

Installation: Post above Emergency Stop

Emergency Stop/Shut-Off Switch: Mount between 42"-46" from grade



Rev:01/2023