



Elevator Equipment Room & Power Shut-off Signage

Requirement:

2021 International Fire Code, Section 604.8: Elevator equipment signage. New and existing buildings with an elevator shall have an approved, visible sign located next to the elevator key box stating the location of the elevator equipment room and elevator power shut-off.

Examples:

**Buildings with dedicated
Elevator Equipment Rooms**



**Buildings without dedicated
Elevator Equipment Rooms**



Minimum Size: 4" Height x 6" Width

Material: Durable, permanently attached.

Sign Color: Any

Lettering: Any Color. Letters must be contrasting with background. No minimum font size must fill sign.

Installation: Approved location. Typically, above the Knox Elevator key box.